

IEC SYSTEM FOR CONFORMITY TESTING
AND CERTIFICATION OF ELECTRICAL
EQUIPMENT (IECEE)
CB SCHEME

SYSTÈME CEI D'ESSAIS DE CONFIRMITÉ
ET DE CERTIFICATION DES EQUIPMENTS
ELECTRIQUES (IECEE)
METHODE OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product
Produit

Residual current operated circuit-breaker

Name and address of the applicant
Nom et adresse du demandeur

Sassin International Electric Shanghai Co., Ltd.
No. 2588 Jinghai Road, Pudong, Shanghai 201209, CHINA

Name and address of the manufacturer
Nom et adresse du fabricant

Same as above

Name and address of the factory
Nom et adresse de l'usine

Same as above

Rating and principal characteristics
Valeurs nominales et caractéristiques principales

$U_e=230V\sim(1P+N)$, $400V\sim(3P+N)$. $I_n=25, 40, 63A$. $I_{\Delta n}=0.03, 0.1, 0.3A$.
Type AC. $I_m=I_{\Delta m}=630A(63A)$, $500A(16\sim40A)$. $I_{nc}=I_{\Delta c}=3kA$

Trade mark (if any)
Marque de fabrication (si elle existe)



Model/type Ref.
Ref. de type

3SL36

Additional information (if necessary)
Information complémentaire (si nécessaire)

-

A sample of the product was tested and
found to be in conformity with
*Un échantillon de ce produit a été essayé et a été
considéré conforme à la*

IEC 61008-2-1:1990
IEC 61008-1:1996 +A1

as shown in the Test Report Ref. No.
which forms part of this certificate
*comme indiqué dans le Rapport d'essais numéro
de référence
qui constitue une partie de ce certificat*

402997-1, -2

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification

Intertek Semko AB
Stockholm

8 April 2004



AKL 

Intertek ETL SEMKO



Postal address
Intertek Semko AB
P.O. Box 1103
SE-164 22 KISTA

Visiting address
Torshamnsgatan 43
KISTA-STOCKHOLM

Telephone
Int +46 8 750 00 00

Telefax
Int +46 8 750 60 30

Certificate



for European Product Safety

Reference No. 402997

Residual current operated circuit-breaker

Type designation	3SL36
Certificate holder	Sassin International Electric Shanghai Co., Ltd. No. 2588 Jinghai Road, Pudong Shanghai 201209 CHINA
The product complies with the standard(s)	EN 61008-2-1:1994 and A11 EN 61008-1:1994 and A2+A11-A15+A17
Date of expiry	8 April 2009
EU Directive information	The product satisfies the provisions for CE marking according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Terms in Intertek Semko's Agreement on certification. Additional information in Appendix.

Certification Body Intertek Semko AB, Product Certification Place Kista - Stockholm

Signed

A handwritten signature in blue ink, appearing to read 'Alve Nilsson', is written over a horizontal line.

Alve Nilsson

Date 8 April 2004

STE



Appendix

Reference No. 402997

Technical data

Type designation	3SL36
Rated voltage (V)	230
Rated current (A)	25, 40, 63
Frequency (Hz)	50/60
IP-Class	20
Pattern No.	2 (1p+N)
Product information	AC type. $I_{\Delta n} = 0.03, 0.1, 0.3A$. $I_m = I_{\Delta m} = 630A$ (63A), 500A (25,40A). $I_{nc} = I_{\Delta c} = 3kA$.


Type designation	3SL36
Rated voltage (V)	400
Rated current (A)	25, 40, 63
Frequency (Hz)	50/60
IP-Class	20
Pattern No.	03 (3p+N)
Product information	AC type. $I_{\Delta n} = 0.03, 0.1, 0.3A$. $I_m = I_{\Delta m} = 630A$ (63A), 500A (25,40A). $I_{nc} = I_{\Delta c} = 3kA$.

Manufacturing site(s)	Sassin International Electric Shanghai Co., Ltd. No. 2588 Jinghai Road, Pudong Shanghai 201209 CHINA
-----------------------	---

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 73/23/EEC and 93/68/EEC.

Certification Body	Intertek Semko AB, Product Certification	Place	Kista - Stockholm
--------------------	--	-------	-------------------

Signed


Alve Nilsson

Date 8 April 2004